

*** BLDG HAS SPRINKLER SYSTEM BUT NO ALARM SYSTEM

*** ELECTRICAL PANELS IN BASEMENT *** FDC & PIV LOCATED ON WEST SIDE NORTHERN ROOF IS BOW STRING TRUSS WITH SPRINKLERS IN THE ATTIC SPACE